



State of Ohio Environmental Protection Agency

Central District Office

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2009

Andy Kerr
814 Shanahan Road
Lewis Center, OH 43035

Re: Storm Water Inspection at Olentangy Bus Facility #2, Future Middle and Elementary School/Permit # 4GC02667*AG

Dear Mr. Kerr:

This letter is written in follow-up to a construction storm water inspection by Heather Nichols and Sean Tyler of the Ohio EPA, at Olentangy Bus Facility #2, Future Middle and Elementary School located at East Side of 3 B'S and AK Road in Lewis Center, Ohio on July 2, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Site is well protected with temporary cover and appears to be in compliance on this date.
- Please continue to maintain stability until such time final grade is achieved.
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Andy Kerr

Page 2

Post Construction Requirements:

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements can be found at: <http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html>.

Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO