



State of Ohio Environmental Protection Agency

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2009

Richard E. Meyers
Franklin County Board of Commissioners
373 South High Street
Columbus, OH 43215

Re: Storm Water Inspection at New Franklin County Courthouse

Dear Mr. Meyers:

This letter is written in follow-up to a construction storm water inspection conducted by Heather Nichols and Clarissa Lawlis, of the Ohio EPA, at the New Franklin County Courthouse located at the west side of South High Street between Mound and Main Street to Front Street on July 7, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The sediment controls implemented on this site appear to be functioning as intended. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kalkopolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/mjs New Franklin County Courthouse July 7, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

