



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

July 22, 2009

Bryan Dougherty  
Performance Site Company  
2323 Performance Parkway  
Columbus, OH 43207

**Re: Storm Water Inspection at Memorial Dr & Pierce Ave Mass Fill  
Fairfield County  
Permit #: 4GC02279\*AG**

Dear Mr. Dougherty:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Heather Nichols, of the Ohio EPA, at Memorial Dr & Pierce Ave Mass Fill located at the corner of Pierce Avenue and State Route 33 in Lancaster, Ohio on July 9, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- Upon inspection it was noted that the perimeter silt fence along the west side of the site has failed and will require repair (See Figure 1).
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Bryan Dougherty  
Performance Site Company  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Memorial Drive & Pierce Ave Mass Fill, 7-9-09

Memorial Dr & Pierce Ave Mass Fill  
Hocking River Watershed  
Photo by: Heather Nichols  
July 9, 2009



Figure 1: Repair silt fence

