



State of Ohio Environmental Protection Agency

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

June 16, 2009

RE: Madison County
Bible Baptist Church of London
Transient Noncommunity Water System
PWSID#: OH4937312

Bible Baptist Church of London
Attn: Robert Goldsmith
91 State Route 56 NW
London, OH 43140

Hand Delivery

Dear Mr. Goldsmith:

Bible Baptist Church of London public water system (PWS) has violated Ohio's safe drinking water law. Specifically, the PWS exceeded the maximum contaminant level for total coliform bacteria, failed to monitor for total coliform bacteria, and failed to provide public notifications for past violations.

Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.

To resolve your drinking water violations and avoid possible legal action and civil penalties, it is agreed that Bible Baptist Church of London will:

1. Within thirty (30) days of the effective date of this agreement, contract with a certified laboratory or a certified operator to collect water samples for total coliform bacteria, nitrate, and nitrite analysis. Submit a copy of the contract for verification to Ohio Environmental Protection Agency (EPA), Division of Drinking and Ground Waters, P.O. Box 1049, Columbus, Ohio 43216-1049, Attn: Ken Baughman.
2. Within fourteen (14) days of the effective date of this agreement, post public notice for past total coliform bacteria monitoring and maximum contaminant level violations. Posting must remain up for no less than seven (7) days. Send a copy of the public notice and completed verification form to address listed in item 1 above.
3. Monitor for total coliform bacteria with a minimum of one routine sample per quarter from the distribution system and perform any required repeat monitoring, in accordance with rule 3745-81-21 of the Ohio Administrative Code.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

4. Comply with the monitoring and reporting requirements in accordance with the 2009 and future contaminant monitoring schedules.

Sincerely,



Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Ken Baughman at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Ken Baughman at (614) 644-2752.

Rob Goldsmith
Signature

6-16-09
Date

Rob Goldsmith
Printed Name

Pastor
Title of Responsible Official