



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 28, 2009

Pastor Virgil Phillips
3653 Big Run South Road
Grove City, OH 43123

Re: House of Blessings Worship Center / Franklin County

Dear Pastor Phillips:

This letter is written in follow-up to a construction storm water inspection that I conducted at the House of Blessings Worship Center located at 3633 Big Run Road, on July 23, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. This also applies to dirt stockpiles. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. In addition, sediment and erosion controls must be intact until at least seventy (70) percent vegetation ground cover is achieved for final stabilization.
- Perimeter silt fencing was installed around the property and along the stream. The silt fence must be inspected weekly or after a significant rain event.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nm House of Blessings Worship Center, 7-23-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

