



State of Ohio Environmental Protection Agency

Central District Office

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 24, 2009

Lisa Dobberstein
DiYanni Homes
1537 Brice Road
Reynoldsburg, OH 43068

Re: Rolling Acres / Fairfield County

Dear Ms. Dobberstein:

This letter is written regarding the storm water inspection that I conducted at Rolling Acres, located along Elder Road, in Lithopolis, Ohio, on July 20, 2009. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

There did not appear to be any active construction at the site during the inspection. However, please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review. Please see attached picture.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,


Gregory L. Sanders
Stormwater Unit
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor DSW/CDO

GS/nsm Rolling Acres, July 20, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Rolling Acres
Walnut Creek Watershed
July 20, 2009
Photo by: Greg Sanders



Rolling Acres
Walnut Creek Watershed
July 20, 2009
Photo by: Greg Sanders



