



State of Ohio Environmental Protection Agency

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 23, 2009

John Hanson
City of Columbus
90 West Broad Street, Suite B-16
Columbus, OH 43215

**Re: Storm Water Inspection at West Side Family Health Center / Franklin County
Permit #: 4GC02525*AG**

Dear Mr. Hanson:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Katie Anderson, of the Ohio EPA, at West Side Family Health Center located at 2300 West Broad Street on July 14, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Upon inspection, it appeared that all of the sediment and erosion controls were functioning as intended. Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Post Construction Requirements:


- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements are found at: [Http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html](http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

John Hanson
City of Columbus
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm West Side Family Health Center, 7-14-09