



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Blazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 23, 2009

Paul Forrester
Ruscilli Construction Company
2041 Arlingate Lane
Columbus, OH 43228

**Re: Storm Water Inspection at Ruscilli Residence / Franklin County
Permit #: 4GC02472*AG**

Dear Mr. Forrester:

This letter is written in follow up to a construction storm water inspection by Amber Miller and Katie Anderson, of the Ohio EPA, at Ruscilli Residence located at 2335 Lane Woods Drive on July 14, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Upon inspection, it appeared that all silt fence has been removed prior to stabilization. Please install silt fence along the street or provide a seed and mulch cover within 3 days from receipt of this letter (See Figure 1).
- In addition, please provide measures to centralize and contain the concrete wash out (See Figure 2).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Ruscilli Residence 7-14-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

1






Figure 1: Install silt fence



Figure 2: Contain concrete washout

1





State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Garzarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 23, 2009

Bob Hoying
555 Metro Place North
Dublin, OH 43017

Re: Storm Water Inspection at New Residential Residence/Permit #4GC02482*AG

Dear Mr. Hoying:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at the residence located at 9233 Hyland Croy Road in Union County on July 7, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The area around the house and near the pond must be stabilized to ensure appropriate protection from erosion (See Photo Figure 1). Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Residence July 7, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director






Figure 1: Area near house requiring protection from erosion

