



State of Ohio Environmental Protection Agency

Central District Office

TELE: (614) 728-3776 FAX: (614) 728-3898
www.epa.state.oh.us

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2009

Mikel Coulter
Nationwide Childrens Hospital
700 Childrens Hospital
Columbus, OH 43205

**Re: Storm Water Inspection at Nationwide Childrens Hospital,
Central Energy Plant / Franklin County**

Dear Mr. Coulter:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Heather Nichols, of the Ohio EPA, at Nationwide Childrens Hospital, Central Energy Plant located at 757 Mooberry Street on July 6, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Upon inspection it appeared that all sediment and erosion controls continue to function properly.

Post Construction Requirements:


The General Permit mandates specific water quality treatment for storm water following the completion of construction (SEE ATTACHMENT). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at harry.kallipolitis@epa.state.oh.us.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Mikel Coulter
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO