



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 14, 2011

John Roslovic
Roslovic Building Company
600 Morrison Road
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Havens Corner Office Park / Franklin County
Permit Number: 4GC02959*AG**

Dear Mr. Roslovic:

This letter is written regarding a storm water inspection I conducted at Havens Corner Office Park located at the corner of Havens Corner Road and Waggoner Road on March 8, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The water collecting in the impoundment intended for sediment controls was NOT functioning as intended. The basin was not accumulating any significant amount of water which is necessary for treatment. The inspection was conducted in conjunction with a significant rain event. ***It was apparent the modified outlet structure intended for sediment control is leaking and must be repaired within seven days from receipt of this letter.***
- In addition, it appears the site is in violation of the 21 day rule which requires stabilization for all barren areas which are idle in excess of 21 days. Corrective measures are expected within 14 days from receipt of this letter.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Havens Corner Office Park 3-8-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

