



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 24, 2011

Michael K Medors
Pharmaforce Inc.
960 Crupper Avenue
Columbus, OH 43229

**Re: Storm Water Inspection at Pharmaforce In
Permit Number: 4GC02909*AG**

Dear Mr. Medors:

This letter is written regarding a storm water inspection I conducted at Pharmaforce Inc. located at the northeast corner of New Albany Road East and State Route 605 on February 9, 2011. I understand this facility is currently covered under Ohio EPA's General Storm Water Permit associated with Construction Activities. Based on my site inspection, the following items were noted:

- **Sediment Controls:** Please be able to demonstrate the centralized sediment basin meets the required storage and de-watering volume as mandated by the General Permit. Please ensure positive drainage is established to direct all barren areas to the pond intended for sediment control. In addition, perimeter controls require maintenance.
- **Erosion Control Requirements:** Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated.
- **Maintenance Requirements:** The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.
- **Post Construction Requirements:** The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

Michael K Medors
Pharmaforce Inc.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Pharmaforce Inc. 02-09-2011