



State of Ohio Enviro

OH1237912 KAFFENBARGER TRUCK EQUIPMENT

22 11/19/07

401 East Fifth Street
Dayton, Ohio 45402-2911

Sout
TELE: (937)285
www



* 0 H 1 2 3 7 9 1 2 6 7 3 0 9 0 8 *

November 19, 2007

RE: CLARK COUNTY
KAFFENBARGER TRUCK EQUIPMENT
NON-TRANSIENT WATER SYSTEM
PWS ID # OH1237912

Kaffenbarger Truck Equipment
10100 Ballentine Pike
New Carlisle, Ohio 45344

Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in August, 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.


Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>

Kaffenbarger Truck Equipment
November 19, 2007
Page 2

Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Southwest District Office of the Ohio EPA.

If you have any questions, please contact me at (937) 285-6114.

Sincerely,



David R. Secor
Compliance Coordinator
Division of Drinking and Ground Waters

Enclosures

cc: Toni Buchanan, DDAGW, CO
Clark County Health Department

DRS\bp

DUPLICATE

Please fill out both sides and return to OHIO EPA within 10 days of posting original

DRINKING WATER NOTICE

Tests showed coliform bacteria in KAFFENBARGER TRUCK EQUIPMENT water

We routinely monitor for the presence of drinking water contaminants. We took Six (6) samples for coliform bacteria for the month of August, 2007. Two (2) of those samples showed the presence of coliform bacteria. No more than [1 sample per month/5 percent of our samples] may show the presence of coliform bacteria during a month.

What should I do?

- **You do not need to boil your water or take other corrective actions.** However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.
- Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution systems.
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*

Fecal coliform or *E. coli*, which are bacteria of greater concern, were not detected in the follow-up testing.

What is being done?

Further testing shows that **coliform bacteria are no longer being detected** and this problem has been resolved.

For more information, please contact _____ at _____ or _____.
name of contact phone number mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWS ID# OH1237912 Date distributed: _____

Tier 2: Resolved Total Coliform Monthly MCL Notice

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR
NONCOMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS**

The owner or operator of a community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <p>1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days) Schools should also send a copy of the notice to the parents of all students.</p> <p>2. Public notice issued by mail or other direct delivery to each customer and service connection (where known).</p>	<p>1A. Dates of posting _____</p> <p>1B. Locations of posting _____ _____</p> <p>1C. Date of notice to parents _____</p> <p>2A. Date of mailing/delivery _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations)</p>	<p>A. Method(s) _____ _____</p> <p>B. Date(s) _____</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

- A public notice as shown on the other side of this sheet was issued without changes.
- A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Official Date

Printed Name and Title of Responsible Official

KAFFENBARGER TRUCK EQUIPMENT
NAME OF PUBLIC WATER SYSTEM
PWSID NUMBER: OH1237912

COUNTY NAME: **CLARK**

<p>For OEPA use only Date PN Received: _____ PN acceptable: PN not acceptable:</p>	<p>VIOLATION TYPE: <u>22</u> MONITORING PERIOD <u>August, 2007</u></p>
--	--

DRINKING WATER NOTICE

Tests showed coliform bacteria in KAFFENBARGER TRUCK EQUIPMENT water

We routinely monitor for the presence of drinking water contaminants. We took Six (6) samples for coliform bacteria for the month of August, 2007. Two (2) of those samples showed the presence of coliform bacteria. No more than [1 sample per month/5 percent of our samples] may show the presence of coliform bacteria during a month.

What should I do?

- **You do not need to boil your water or take other corrective actions.** However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.
- Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution systems.
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*

Fecal coliform or *E. coli*, which are bacteria of greater concern, were not detected in the follow-up testing.

What is being done?

Further testing shows that **coliform bacteria are no longer being detected** and this problem has been resolved.

For more information, please contact _____ at _____ or _____.
name of contact phone number mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWS ID# OH1237912 Date distributed: _____

Tier 2: Resolved Total Coliform Monthly MCL Notice

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NONCOMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <p>1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days) Schools should also send a copy of the notice to the parents of all students.</p> <p>2. Public notice issued by mail or other direct delivery to each customer and service connection (where known).</p>	<p>1A. Dates of posting _____</p> <p>1B. Locations of posting _____</p> <p>1C. Date of notice to parents _____</p> <p>2A. Date of mailing/delivery _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations)</p>	<p>A. Method(s) _____</p> <p>B. Date(s) _____</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

- A public notice as shown on the other side of this sheet was issued without changes.
- A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Official Date

Printed Name and Title of Responsible Official

KAFFENBARGER TRUCK EQUIPMENT
NAME OF PUBLIC WATER SYSTEM

PWSID NUMBER: OH1237912

COUNTY NAME: CLARK

For OEPA use only

Date PN Received: _____

PN acceptable: _____ PN not acceptable: _____

VIOLATION TYPE: 22

MONITORING PERIOD August, 2007