



State of Ohio Environmental Protection Agency

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 2, 2009

RE: Clark County
Heritage Fellowship Church
Transient Noncommunity Water System
PWSID#: OH1247412

Attn: Kirk Hildreth, Pastor
Heritage Fellowship Church
105 N. Tecumseh Rd.
Springfield, OH 45504

Hand Delivery

Dear Pastor Hildreth:

Heritage Fellowship Church public water system (PWS) has violated Ohio's safe drinking water law. Specifically, the PWS exceeded the maximum contaminant level (MCL) for total coliform bacteria, failed to monitor for total coliform bacteria, failed to collect the required number of total coliform bacteria samples after a total coliform-positive sample, and failed to provide public notifications for past violations.

Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.

To resolve your drinking water violations and avoid possible legal action and civil penalties, it is agreed that Heritage Fellowship Church will:

1. Within thirty (30) days of the effective date of this agreement, post public notice for past total coliform bacteria MCL and monitoring violations. Posting must remain up for no less than seven (7) days. Send a copy of the public notice and completed verification form to Ohio Environmental Protection Agency (EPA), Division of Drinking and Ground Waters, P.O. Box 1049, Columbus, Ohio 43216-1049, Attn: Ken Baughman.
2. Monitor for total coliform bacteria with a minimum of one routine sample per quarter from the distribution system and perform any required repeat monitoring, in accordance with rule 3745-81-21 of the Ohio Administrative Code.
3. Comply with the monitoring and reporting requirements in accordance with the 2009 and future contaminant monitoring schedules.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

4. Post public notice for any future total coliform MCL and monitoring violations in accordance with rule 3745-81-32 of the Ohio Administrative Code.
5. Within sixty (60) days of the effective date of this agreement, investigate the source of total coliform bacteria contamination and submit findings to the address listed in item 1 above.

Sincerely,



Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Ken Baughman at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Ken Baughman at (614) 644-2752.

H Kirk Heldreth

Signature of Responsible Official

H Kirk Heldreth

Printed Name

9/2/09

Date

Senior Pastor

Title of Responsible Official