



State of Ohio Environmental Protection Agency

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

October 13, 2009

Millers Corner
Mike & Kellie Miller
984 Dubois Road
Carlisle, Ohio 45005

RE: Warren County
Millers Corner
Transient Water System
PWSID#: 8361112

"Hand Delivery (or certified mail)"

Dear Mr. & Mrs. Miller:

The Millers Corner public water system (PWS) has violated Ohio's safe drinking water law. Specifically, the PWS has failed to monitor for total coliform bacteria, failed to monitor for nitrate, failed to provide public notifications for past violations and has not paid the 2009 License to Operate (LTO) fee.

Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.

To resolve your drinking water violations, remain in compliance and avoid possible legal action that could include civil penalties, it is agreed that Millers Corner will:

1. Within fourteen (14) days of the effective date of this agreement, post public notice for past total coliform bacteria and nitrate monitoring violations. Posting must remain up for no less than seven (7) days in accordance with Ohio Administrative Code (OAC) Rule 3745-81-32. Send a copy of the public notice and completed verification form to the Ohio Environmental Protection Agency (EPA), Division of Drinking and Ground Waters, P.O. Box 1049, Columbus, Ohio 43216-1049, Attn: Julie Gillenwater.
2. In accordance with OAC Rule 3745-81-21, monitor for total coliform bacteria with a minimum of one routine sample per quarter from the distribution system and perform any required repeat monitoring.
3. Comply with the monitoring and reporting requirements in accordance with the 2009 and all future contaminant monitoring schedules.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

4. Complete an application and submit the required fee for the current year's LTO. This fee (\$137.62) has currently been sent for collections by the Attorney General's Office (AGO).
5. In the future, remain current with your licensing requirements (ORC § 6109.21) by submitting a renewal application along with the payment of the appropriate fee by December 31 of each year. (Note: Due to the 2009 compliance record, the LTO for 2010 may be issued with conditions.)
6. Contract with a certified laboratory to collect and analyze the required samples for twelve (12) months to help meet regulatory requirements and establish a routine of compliance. Within thirty (30) days of the effective date of this agreement, submit a copy of the completed contract to Ohio Environmental Protection Agency (EPA), Division of Drinking and Ground Waters, P.O. Box 1049, Columbus, Ohio 43216-1049, Attn: Julie Gillenwater.

Sincerely,



Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Julie Gillenwater at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Julie Gillenwater at (614) 644-2752.



Mike Miller
Millers Corner

10-13-09

Date

Kellie Miller
Millers Corner

Date