



\*4GC0303720110120\*

2011/01/20

4GC03037

HIGHLAND LOCAL SCHOOLS



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 21, 2011

Tim Hiborn  
Highland Local Schools  
6506 State Route 229  
Sparta, OH 43350

**Re: Construction Storm Water Inspection of Permit Number 4GC03039\*AG**

Dear Mr. Hiborn:

This letter is written in follow up to a storm water inspection I conducted of the construction activities associated with Highland Local Schools in Sparta, Ohio on January 13, 2011. The purpose of the inspection was to evaluate compliance with your "Construction Storm Water Permit associated with Construction Activities" issued by Ohio EPA. Based on my site inspection and the conditions of the permit the following items will require attention:

**Sediment and Erosion Controls:**

- The centralized storm basin did not appear to be modified for sediment control. Corrective measures are expected within 10 days from receipt of this letter to modify the outlet structure to address a sediment storage volume of 37 cubic yards per acre of disturbance and a dewatering zone of 67 cubic yards per acre of drainage. The dewatering orifice must size to accommodate a dewatering time of no less than 48 hours. The modification must remain until all barren areas are protected from erosion measures by a vegetative density of at least 70 percent
- All perimeter controls must be inspected and maintained.
- All barren areas must be protected from erosion concurrent with the winter months. Given the time of year crimped mulch cover or equivalent is expected.

**Post Construction Requirements:**

- The general permit mandates specific post construction water quality treatment following the completion of construction. Please submit to my attention, (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) all post construction measures, including design criteria to demonstrate compliance.


Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

Tim Hiborn  
Highland Local Schools  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844. In addition please provide a response to this letter (email preferred) within seven days of receipt.

Sincerely,



Harry Kallipolitis  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Recycle Exchange Inc.