



4GC0331420110120

2011/01/20

4GC03314

OLDE ORCHARD ELEMENTARY SCHOOL



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 20, 2011

Ron Strussion
Reynoldsburg City School
7244 E Main Street
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Olde Orchard Elementary School
800 McNaughten Road, Reynoldsburg, Ohio 43213**

Dear Mr. Strussion:

This letter is written in follow-up to a construction storm water inspection I conducted at Olde Orchard Elementary School on January 4, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Perimeter silt fence is installed. The silt fence along the eastern perimeter is compromised due to recent precipitation events. Corrective measures are expected to ensure all silt fence is properly installed.
- All barren areas, which remain idle through the winter, must be protected from erosion. Given the time of year, a crimped mulch cover or equivalent is expected.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: [Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ron Strussion
Reynoldsburg City School
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW