



4GR0021320110107

2011/01/07

4GR00213

GE - CIRCLEVILLE LAMP PLANT



Environmental
Protection Agency

John Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 10, 2011

Troy Smith
GE Circleville Lamp Plant
599 East Ohio Street
Circleville, OH 43113

**Re: GE Circleville Lamp Plant, Pickaway County
Industrial Storm Water Permit 4GR00213*DG**

Dear Mr. Smith:

This letter is written in regard to the storm water inspection that I conducted at GE Circleville Lamp Plant, located at 599 East Ohio Street, in Circleville, Ohio. The inspection was conducted on January 5, 2011, to determine compliance with your industrial storm water permit. Your facility manufactures fluorescent lamps. Your facility appeared to be in compliance with its industrial storm water permit. The following items were noted during the inspection:

1. A storm water pollution prevention plan (SWP3) and a spill prevention plan were developed for this facility. Please update these plans annually or when there is a change in management.
2. Inspections were conducted weekly and the logs kept on-site.
3. The facility had spill kit containers located throughout the facility and by the loading/unloading areas. Emergency contact lists were posted at the spill kit containers.
4. The dumpsters were covered and located under roof.
5. The parking lot was free from staining.
6. All outside tanks were in secondary containment. A protocol for dewatering containment areas were posted at the containment area.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

GS/nsm GE Circleville Lamp Plant, January 5, 2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

