



4GC0322920110106

2011/01/06

4GC03229

MAIN ST IN WESTERVILLE BRIDGE RPLMT OVER
ALUM CRK



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

January 7, 2011

Mike Bashore
Franklin County Engineer
970 Dublin Road
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Main Street in Westerville Bridge Replacement Over Alum Creek/Franklin County.
Permit Number: 4GC03229*AG**

Dear Mr. Bashore:

This letter is written regarding the storm water inspection I conducted at the Main Street Bridge Replacement over Alum Creek located in Westerville Ohio on December 17, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

Sediment and Erosion Controls:

- It appears majority of the sediment and erosion controls are in place and functioning as intended.
- Barren areas were frozen and appeared stable during the inspection.
- Please ensure all controls are maintained during the winter months.

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition... This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Mike Bashore
Franklin County Engineer
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO