



4GR0054420110106

2011/01/06

4GR00544

PETERMANN



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

January 7, 2011

John Borcher
Petermann LTD.
8401 Hosbrook Road, Suite 330
Cincinnati, OH 45236

**Re: Preliminary Storm Water Inspection at Peterman LTD., Johnstown, Ohio
Permit Number (4GR00544*DG)**

Dear Mr. Borcher:

This letter is written in follow-up to a preliminary storm water inspection I conducted at Petermann Ltd. Located at 6097 Johnstown-Utica Road in Johnstown, Ohio on December 28, 2011. This facility is currently covered under the General Storm Water Permit Associated with Industrial Activities. This preliminary inspection entailed the evaluation of materials and or processes exposed to storm water. Based on my preliminary inspection, the following items were noted:

Observations:

- Large diesel storage tank noted with apparent secondary containment. Please indicate in your response the secondary containment volume and the volume of the tank.
- A secondary containment loading and unloading pad should be considered for this facility.
- All vehicle wash water associated with vehicle or equipment washing must be collected to ensure proper disposal.
- Please indicate in your response if there are inside drains at the maintenance facility and where they discharge.

Storm Water Pollution Prevention Plan (SWPPP)

- A SWPPP must be developed specific for this site. The SWPPP must include a site map which clearly delineates all storm water drainage patterns. All storm water outfalls/discharges from the site must be identified on the SWPPP. All Best Management Practices (BMP's), current and future must be inclusive in the SWPPP and site map. The SWPPP must be reviewed and updated on a yearly basis to reflect any changes at this facility. Guidance documents for preparing/updating your SWPPP can be found at:

http://www.epa.gov/npdes/pubs/industrial_swppp_guide.pdf

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

John Borchert
Petermann LTD.
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the requested items in this letter within 10 days of receipt.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Petermann Ltd 12-28-2010