

4GC0330520110106

2011/01/06

4GC03305

GAMBIER ROAD AT EDGEWOOD ROAD
INTERSECTION



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Garza Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

January 6, 2011

Cameron Keaton
City of Mount Vernon
40 Public Square
Mount Vernon, OH 43050

**Re: Notice of Termination Inspection at Gambier Road at Edgewood Road
Permit Number 4GC03305*AG**

Dear Mr. Keaton

This letter is written in follow up to a construction storm water inspection I conducted at **Gambier Road at Edgewood Road** located at Mount Vernon, Ohio on December 28, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction requirements are met:

- The successful establishment of vegetation measure by a minimum vegetative density of 70 percent.
- The General Storm Water Permit requires specific post construction water quality *treatment for all sites*. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction and vegetative density requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Cameron Keaton
City of Mount Vernon
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Gambier Road At Edgewood 12-28-2010