



4GC0312920101228

2010/12/28

4GC03129

ETNA PARKWAY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Garus Government Center
60 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

December 28, 2010

Jerry Brems
Licking County
20 South Second Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at Etna Parkway / Licking County
Permit Number: 4GC03129*AG (NOTICE OF VIOLATION)**

Dear Mr. Brems:

This letter is written regarding the storm water inspection I conducted at **Etna Parkway** located between US 40 and Refugee Road in Pataskala, Ohio on December 1, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

I had the opportunity to conduct a storm water inspection of the construction activities associated with Etna Parkway South on 12-01-2010. During the inspection, I evaluated the sediment and erosion controls. As you aware, this section of road is located very close to some very high quality wetlands. I am very concerned with the apparent lack of sediment control maintenance noted during the inspection. I noted the following:

- The perimeter silt fence is failing throughout the project especially along the western edge of the affected area. Failure to maintain silt fence is a direct violation of the General Permit. Corrective measure are expected to re-install/maintain all perimeter silt fence by Monday December 6, 2010.
- The entire site must be protected from erosion with a crimped mulch cover or equivalent by December 15, 2010. This would include the road base, fill slopes, the large stockpile on the northern end of the project, and the barren areas associated with the storm water impoundment.
- Failure to address the corrective measures listed above within the required time frames may result in escalated enforcement against the permittee and contractor. Alternate time frames must be evaluated and approved by our office.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



- Notification of the inspection and corrective measures were brought to your attention via an email on December 2, 2010.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition please provide a written response within five days from receipt of this letter.

Sincerely,



for H.K.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO