



\*4GC0323520101207\*

2010/12/07

4GC03235

WORTHINGTON-GALENA RD & WORTHINGTON RD  
IMPROVEMENT



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

December 8, 2010

Jeff Kessler  
City of Westerville  
64 East Walnut Street  
Westerville, OH 43081

**Re: Storm water inspection at Worthington Galena Road Improvement  
Franklin County  
Permit Number 4GC03235\*AG**

Dear Mr. Kessler:

This letter is written in follow-up to a construction storm water inspection I conducted at Worthington Galena Road and Lazelle Road at I-71, Westerville, Ohio on November 16, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted

**Sediment and erosion controls:**

- The majority of the site construction is complete.
- I noted vast areas which were recently stabilized with seed and mulch. The mulch did not appear crimped. Please be aware in the event mulch blows off-site, an additional application is expected. I would advise implementing measures to secure the mulch cover to avoid this cost.
- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Worthington Galena Road Improvements 9-30 and 10-5-2010  
Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



