



4GC0164520101117

2010/11/17

4GC01645

WHITE OAK COMMERCIAL CENTER



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 17, 2010

Jason Gunsorek
Anchor Companies
7760 Olentangy River Road #112
Columbus, OH 43235

Re: White Oak Commercial Center / Franklin County

Dear Mr. Gunsorek:

This letter is written regarding the storm water inspection that I conducted at the White Oak Commercial Center located along Gender Road, on November 10, 2010. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. The following was noted during my inspection:

Sediment and Erosion Controls:

There was limited construction activity at the site during my inspection. The site appeared to be stabilized and no erosion was leaving the site. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.

Please maintain the erosion controls at the site. The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm White Oak Commercial Development, Nov. 10, 2010
Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

