



4GC0317220101117

2010/11/17

4GC03172

SP RICHARDS



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Cazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 17, 2010

Martin Fitch
Exxcel Project Management Inc.
2 Miranova Place
Suite 250
Columbus, OH 43215

Re: SP Richards, Franklin County

Dear Mr. Fitch:

This letter is written in follow up to a construction storm water inspection that I conducted at the SP Richards site located at 2410 McGaw Road, on November 9, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

Some of the site has been seeded. However, there is a large portion of the site that needs to have the barren areas stabilized. Vegetation must cover at least 80% of the area. Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months. Please see attached pictures.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office


c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm SP Richards, November 9, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



SP Richards
Maintain vegetative cover at 80%
Alum Creek Watershed
November 9, 2010
Photo by: Greg Sanders



SP Richards
Maintain vegetative cover at 80%
Alum Creek Watershed
November 9, 2010
Photo by: Greg Sanders

