



4GC0285220101117

2010/11/17

4GC02852

WALNUT C & DD FACILITY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 17, 2010

Rusty Mock
Walnut C&DD Facility
8675 Lancaster-Newark Road
Baltimore, OH 43105

Re: Walnut C&DD Facility / Fairfield County

Dear Mr. Mock:

This letter is written regarding the storm water inspection I conducted of the construction activities at Walnut C&DD, located at 8675 Lancaster-Newark Road, on November 12, 2010. Thank you for taking the time to inspect the site with me. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following was noted:

Sediment and Erosion Controls:

The site was stabilized and no erosion was leaving the site. You appeared to be in compliance with your general storm water construction permit. There was a small working face on a stockpile of topsoil during my site visit. You stated that this area would be stabilized as soon as the job was completed.

It was noted that the existing check dams consisting of silt fence and straw bales were operating properly. It was discussed that the area to the south of the office, and the current location of the check dams, may become a sediment basin. I stated that this would be a good alternative to check dams and recommended that the sediment basin have a riser with filter fabric on the discharge outlet. I also suggested that the outlet have a gate valve that would enable you to plug the discharge from the sediment pond.

Please continue to maintain your existing controls. If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO
Jerry and Barbara Mock

GLS/nsm Walnut C&DD Facility, November 12, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



