



4GC0325520101116

2010/11/16

4GC03255

FRENCH RUN ELEMENTARY SCHOOL



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 17, 2010

Ron Strussion
Reynoldsburg City School
7244 E Main St.
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at French Run Elementary
Permit Number 4GC03255*AG**

Dear Mr. Strussion,

This letter is written in follow-up to a construction storm water inspection I conducted at Commerce Fire Training Academy, Driver Training Lot on November 8, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Perimeter silt fence is installed with the exception of the southeast corner. This area drains down towards an existing parking lot and onto French Run. Please ensure all perimeter controls are properly maintained within three days from receipt of this inspection. This area should be evaluated for the implementation of a sediment trap in the event the design criteria for silt fence is exceeded.
- The northern field is barren and must be protected from erosion in preparation for the upcoming winter months. All barren areas which remain idle through the winter must be protected from erosion. Given the time of year, a crimped mulch cover or equivalent is expected.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: [Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ron Strussion
Reynoldsburg City School
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm French Run Elementary 11-08-2010