



4GC0338220101116

2010/11/16

4GC03382

COMMERCE FIRE TRAINING ACADEMY DRIVER
TRAINING



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 17, 2010

Donald Cooper
Ohio Department of Commerce, Division of State Fire Marshal
8895 East Main Street
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Commerce "Fire Training Academy,
Driver Training Lot / Franklin County
Permit Number 4GC03382*AG**

Dear Mr. Cooper:

This letter is written in follow-up to a construction storm water inspection I conducted at Commerce Fire Training Academy, Driver Training Lot on November 8, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The majority of construction is complete.
- I noted the seed and mulch contractor onsite working on final erosion control measures. Please continue with these efforts until all areas are protected from erosion.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: [Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Donald Cooper
Ohio Department of Commerce, Division of State Fire Marshal
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at: harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW