



4GCD000620101112

2010/11/12

4GCD0006

HAMILTON RUN



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 15, 2010

James Ramsey
Franklin County Engineers Office
970 Dublin Road
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Hamilton Run Stream Restoration
Franklin County
Permit Number 4GCD00065*AG**

Dear Mr. Ramsey:

This letter is written in follow-up to a construction storm water inspection I conducted at the Hamilton Run Stream Restoration between Alton Darby Creek Road and Roberts Road on November 4, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appears that construction is near completion. I noted the site is protected with a seed and mulch cover. It appears final vegetative plantings are nearly completed.
- Please continue with your self-monitoring every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm Hamilton Run Stream Restoration 11-04-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



