



\*4GR004962010112\*

2010/11/12

4GR00496

HEARTLAND EXPRESS INC



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

November 15, 2010

Kevin Kusner  
Heartland Express Inc.  
901 North Kansas Street  
North Liberty, IA 52317

**Re: Heartland Express Inc. / Franklin County  
Industrial Storm Water Permit 4GR00496\*DG**

Dear Mr. Kusner:

This letter is written in regard to the storm water inspection that I conducted at Heartland Express Inc., located at 1850 Lone Eagle Drive, Columbus, Ohio. The inspection was conducted on November 5, 2010, to determine compliance with your industrial storm water permit. Your facility is a trucking and distribution company and I was accompanied on the inspection by Walt Millenke, shop manager. The following items were noted during the inspection:

1. The truck parking area drains to an oil-water separator. Capitol City pumps out the oil-water separator every six months.
2. The fueling station was located under roof. Please include a spill kit and an emergency contact list at the fueling station.
3. There were used truck parts (brake pads) stores outside in an uncovered dumpster. Use truck parts should be stored in an enclosed dumpster or inside a building.
4. There was excessive oil staining on the pavement at the garage doors to the maintenance shop and at a dumpster near the fueling station. Please use oil absorbent and better housekeeping to prevent oil from staining the pavement. Please see attached pictures.
5. A storm water pollution prevention plan and a spill prevention plan will need to be developed for this facility. The plans will need to be updated annually and kept on-site.
6. The inspections listed in your storm water pollution prevention plan will need to be completed per the frequency listed in the plan.


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Kevin Kusner  
Heartland Express Inc.  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,



Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, DSW/CDO  
Walt Millenke, Heartland Express, Inc.  
Scott Shields, City of Columbus, DOSD

GS/nsm Heartland Express Inc., November 5, 2010

Heartland Express, Inc.  
Scioto River Watershed  
November 5, 2010  
Photo by: Greg Sanders



Heartland Express Inc.  
Oil staining near maintenance shop  
Use absorbent material  
Scioto River Watershed  
November 5, 2010  
Photo by: Greg Sanders

