



4GR0047620101112

2010/11/12

4GR00476

CRETE CARRIER CORP - TERMINAL #243



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 15, 2010

Scott Clay
Crete Carrier Corporation
P.O. Box 81228
Lincoln, NE 68501

**Re: Crete Carrier Corporation Terminal #243 / Franklin County
Industrial Storm Water Permit 4GR00476*DG**

Dear Mr. Clay:

This letter is written in regard to the storm water inspection that I conducted at Crete Carrier Corporation Terminal #243, located at 5400 Crosswind Drive, Columbus, Ohio. The inspection was conducted on November 5, 2010, to determine compliance with your industrial storm water permit. Your facility is a trucking and distribution company and I was accompanied on the inspection by Steve Hudson, shop manager. The following items were noted during the inspection:

1. The truck parking area drains to an oil-water separator. Northstar pumps out the oil-water separator on a quarterly schedule.
2. The fueling station was located under roof and included a spill kit and an emergency contact list.
3. There were used truck parts (brake pads) stores outside in an uncovered dumpster that was leaking to a storm water drain. This dumpster should be relocated to a site away from storm water drains. Use truck parts should be stored in an enclosed dumpster or inside. Please see attached pictures.
4. There was minor oil staining on the pavement at the garage doors to the maintenance shop. Please use oil absorbent and better housekeeping to prevent oil from staining the pavement. Please see attached pictures.
5. The inspections listed in your storm water pollution prevention plan need to be completed per the frequency listed in the plan.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Koreski, Director



Scott Clay
Crete Carrier Corporation
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,



Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO
Steve Hudson, Crete Carrier Corporation
Scott Shields, City of Columbus, DOSD

GS/nsm Crete Carrier Corp, November 5, 2010

Crete Carrier Corp. Terminal #243
Remove dumpster from storm drain
Cover dumpster or move inside
Scioto River Watershed
November 5, 2010
Photo by: Greg Sanders



Crete Carrier Corp. Terminal #243
Oil staining near maintenance shop
Use absorbent material
Scioto River Watershed
November 5, 2010
Photo by: Greg Sanders



