



4GC0312920101109

2010/11/09

4GC03129

ETNA PARKWAY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 10, 2010

Jerry Brems
Licking County
20 South Second Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at Etna Parkway / Licking County
Permit Number: 4GC03129*AG**

Dear Mr. Brems:

This letter is written regarding the storm water inspection I conducted at **Etna Parkway** located between US 40 and State Route 16 in Pataskala, Ohio on October 7, and November 4, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- The clearing activities associated with "Etna South" have commenced.
- Perimeter silt fence is currently the chosen BMP.
- Once concentrated flow is established either through installation of road side ditches or by grading activities, the sediment traps are expected
- ***All barren areas which remain idle over the winter months MUST be protected from erosion, given the time of year; a crimped mulch cover is expected. Please ensure the mulch is crimped and not just broadcasted over the grounds.***

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm ETNA Parkway 10-7-and 11-5-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

