



4GCO000120101109

2010/11/09

4GCO0001

OHIO MULCH



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 10, 2010

Bill Cashman
Greenwood II LLC.
1748 US Highway 42 North
Delaware OH 43015

**Re: Construction Storm Water Inspection at Ohio Mulch / Delaware County
Permit Number: 4GCO00012*AG**

Dear Mr. Cashman:

This letter is written regarding the storm water inspection; I conducted at **Ohio Mulch** located on **North East of US 42 and Shortcut Road Intersection**, Delaware on November 2, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

Sediment Erosion Controls:

- The site was void of sediment controls during the inspection resulting in a direct **violation** of your General Storm Water Permit. Corrective measures are expected with three days from receipt of this letter to install the controls in accordance with your approved Storm Water Pollution Prevention Plan
- Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. **Given the time of year, a crimped mulch cover or equivalent is expected in preparation for the upcoming winter months.**

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm Ohio Mulch Delaware 7-8-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

