



4GC0335420101109

2010/11/09

4GC03354

VILLAGE CHAPEL OF ASHVILLE



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 10, 2010

Pastor Aaron Brown
Village Chapel of Ashville
30 Circleville Avenue
Ashville, OH 43103

Re: Village Chapel of Ashville / Pickaway County

Dear Pastor Brown:

This letter is written regarding a meeting that was held at the request of your contractor, Craig Foster, to discuss your parking lot project located at 30 Circleville Avenue, in Ashville, Ohio. The meeting was held on November 3, 2010. The purpose of the meeting was to discuss sediment and erosion controls during construction of the parking lot and the enlarging of the sediment pond. The Ohio EPA agreed to allow an earthen berm to be used in lieu of using silt fence for the site. The earthen berm would be constructed from approximately the northeast corner of the site and connect to the southeast corner of the sediment pond. The earthen berm would direct storm water run-off to the sediment basin and prevent sediment from being discharged off-site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Craig Foster, Foster Maintenance

GS/nsm Village Chapel, November 3, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

