



4GC0324220101108

2010/11/08

4GC03242

BIG BOY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Cazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 8, 2010

Dan Botter
Frisch's Restaurant Inc.
2800 Gilbert Ave.
Cincinnati, OH 45206

**Re: Construction Storm Water Inspection at Big Boy – Heath, Ohio
Licking County
Permit Number 4GC03242*AG**

Dear Mr. Botter:

This letter is written in follow-up to a construction storm water inspection I conducted at Big Boy located on Hebron Road in Heath, Ohio on October 27, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- I noted the installation of sediment controls along Hebron Road. In addition, I noted the installation of inlet protection to minimize sediment transport to the storm sewer system
- Currently the site excavation is proceeding in such a manner where storm water is currently contained. Once positive off-site storm water flows are established additional sediment controls are expected.

Post Construction Requirements:

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:


<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Dan Botter
Frisch's Restaurant Inc.
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Big Boy Heath, 10-1-27, 2010