



4GC0326620101108

2010/11/08

4GC03266

TIRE DISCOUNTERS STORE - HEALTH



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 8, 2010

David Wilson
Tire Discounters Inc.
7525 Wooster Pike
Cincinnati, OH 45227

**Re: Construction Storm Water Inspection at Tire Discounters Store – Heath
Licking County
Permit Number 4GC03266*AG**

Dear Mr. Wilson:

This letter is written in follow-up to a construction storm water inspection I conducted at Tire Discounters Store located at 1041 Hebron Road in Heath, Ohio on October 29, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Portions of the perimeter silt fence are missing. Please ensure the entire perimeter of the site is protected with silt fence or demonstrate an approvable alternative
- The silt fence along the perimeters of the project must be trenched into the ground for proper functioning as intended. Corrective measures are expected within three days from receipt of this letter.

Post Construction Requirements:

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:


<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

David Wilson
Tire Discounters Inc.
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO