



4GC0273620101029

2010/10/29

4GC02736

LONDON CHURCH OF CHRIST



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 1, 2010

Reverend Wendell Hurley
London Church of Christ
316 Harrington Drive
London, OH 43140

Re: London Church of Christ / Madison County

Dear Reverend Hurley:

This letter is written in follow-up to a construction storm water inspection that I conducted at the London Church of Christ located on Westmoor Drive in London, Ohio, on October 20, 2010. I noted that your church was recently constructed. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Erosion controls need to be installed around the barren areas, such as silt fence. Please be aware that silt fencing and other erosion controls are required to be inspected weekly or after a significant rain event.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. The barren areas appeared to be at final grade. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.


Sincerely,


Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/hsm London church of Christ, October 20, 2010
Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director







London Church of Christ
Stabilize barren areas
Install silt fence
Deer Creek Watershed
October 20, 2010
Photo by: Greg Sanders



London Church of Christ
Stabilize barren areas
Install silt fence
Deer Creek Watershed
October 20, 2010
Photo by: Greg Sanders

