



4GC0319320101029

2010/10/29

4GC03193

LONDON MIDDLE SCHOOL



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 1, 2010

D Steven Allen
London City School Dist
60 S Walnut Street
London, OH 43140

Re: London Middle School / Madison County

Dear Mr. Allen:

This letter is written in follow-up to a construction storm water inspection that I conducted at the London Middle School located at between 336 Elm Street and 380 Elm Street, in London, Ohio, on October 20, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection, it was noted that all previous concerns with regards to the retention pond and discharge storage have been adequately addressed. Please inspect and maintain sediment controls every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches to ensure continued effectiveness of the sediment basin. Your inspection log did not show any previous inspection for two weeks prior to my inspection.
- Please be aware measures are expected to ensure all barren areas including the stockpiles in the rear of the site are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm London Middle School, October 20, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



