



\*4GC0326020101029\*

2010/10/29

4GC03260

BRIDGESTONE/FIRESTONE AUTO SERVICE FACILITY



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

November 1, 2010

Chris Kloiberjohn Burkemper  
Amcon Design & Construction Co LLC  
20633 Watertown Court, Suite 200  
Waukesha, WI 53186

**Re: Bridgestone/Firestone Auto Service Facility / Franklin County**

Dear Mr. Burkemper:

This letter is written in follow-up to a construction storm water inspection that I conducted at Bridgestone/Firestone Auto Service Facility located near Waterloo and Gender Roads, in Canal Winchester, Ohio, on October 25, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- A concrete wash-out pit was installed for this site as requested.
- You stated that gravel will be placed on the site early next week and blacktop placed at the site later in the week. If this schedule is delayed, please use alternative measures to prevent mud from being tracked off-site. Continue to remove sediment from the road as needed.
- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. *There were several sections of silt fence that needed to be installed and maintained. A log of the inspections was up-to-date and maintained on site for the agency to review.*

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Bridgestone Firestone Auto Service Facility, 10/25/10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



