



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

March 30, 2010

RE: Ashtabula County  
Treasure Island  
Transient Noncommunity Water System  
PWSID#: OH0441712

Treasure Island  
Attn: Bruce Goodrick  
5611 Pymatuning Lake Rd.  
Andover, OH 44003

Hand Delivery

Dear Mr. Goodrick:

Ohio Environmental Protection Agency (EPA) acknowledges that Treasure Island public water system (PWS) is under new management and that violations occurred to Ohio's safe drinking water law under the former management. Specifically, the PWS exceeded the maximum contaminant level (MCL) for total coliform bacteria, failed to monitor for total coliform bacteria and collect required repeat samples, failed to monitor for nitrates, failed to properly secure well cap and properly grade around the well head, and failed to provide public notifications for past violations.

**Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.**

To resolve these past drinking water violations and bring the public water system back into compliance, it is agreed that Treasure Island will:

1. Within fourteen (14) days of the effective date of this agreement, post public notices for past violations for no less than seven (7) days in accordance with Ohio Administrative Code (OAC) Rule 3745-81-32. Send a copy of the public notice and verification forms to Ohio Environmental Protection Agency (EPA), Northeast District Office (NEDO), Division of Drinking and Ground Waters, Attn: Dave Maschak, 2110 E. Aurora Road, Twinsburg, Ohio 44087. A public notice and verification form that can be used to comply with this requirement is attached.
2. Monitor for total coliform bacteria with a minimum of one routine sample per quarter from the distribution system and perform any required repeat monitoring, in accordance with rule 3745-81-21 of the Ohio Administrative Code (OAC).

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

3. Comply with the monitoring and reporting requirements in accordance with the 2010 and future contaminant monitoring schedules.
4. Comply with all PWS license to operate renewal requirements in accordance with OAC Rule 3745-84-01(C).
5. Within forty-five (45) days of notification by Ohio EPA, per OAC 3745-81-60 (D), make corrections of any well deficiencies that may be noted during your next inspection and send verification according to the inspection letter.

Sincerely,



Michael G. Baker, Chief  
Division of Drinking and Ground Waters

Enclosures: Public Notice & Verification Form

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Ken Baughman at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Ken Baughman at (614) 644-2752.

  
\_\_\_\_\_  
Signature

3-30-10  
Date

Bruce Goodrick  
Printed Name

Manager  
Title of Responsible Official