



\*4GC0315220101029\*

2010/10/29

4GC03152

MEADOW GROVE SOUTH SECTION 8



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

November 1, 2010

Don Wick  
Rockford Homes  
999 Polaris Parkway  
Columbus, OH 43240

**Re: Meadow Grove South, Sec. 8 / Franklin County  
Notice of Violation**

Dear Mr. Wick:

This letter is written regarding the storm water inspection that I conducted near the intersection of Blue Star Drive and Deergrass Court, in Grove City, Franklin County, on October 27, 2010. The agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Please consider this a formal notice of violation. You will need to address the issues below or face escalated enforcement. The entire site was completely barren with little or no erosion controls. Based on the site inspection and the General Storm Water Permit, the following items must be addressed under the storm water permit.

**Sediment and Erosion Controls:**


- The site lacked erosion controls except for a few dandy bags which needed maintenance. Sediment was eroding on to the road. Please install erosion controls immediately, such as straw waddles and silt fence. The erosion controls must be maintained and inspected weekly or after a significant rain event. A log of the inspections must be kept on-site. Please send me a copy of the log of inspections from the January 1, 2010, to the present. Please see attached pictures.
- Be aware the General Permit states that all barren areas including stockpiles which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. The site appeared to be near final grade. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.
- Please remove the sediment from the road.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Don Wick  
Rockford Homes  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,




Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

GS/nsm Meadow Grove Estates North, October 27, 2010

Meadow Grove South, Sec. 8  
Stabilize barren areas  
Install / maintain erosion controls  
Remove sediment from street  
Spoto River Watershed  
October 27, 2010  
Photo by: Greg Sanders



Meadow Grove South, Sec. 8  
Stabilize barren areas  
Install / maintain erosion controls  
Remove sediment from street  
Spoto River Watershed  
October 27, 2010  
Photo by: Greg Sanders



