



4GC0312620101112

2010/11/12

4GC03126

RUMPKE RECYCLING AND TRANSFER STATION



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 15, 2010

David Murphy
Rumpke
10795 Hughes Rd
Cincinnati, OH 43103

**Re: Construction Storm Water Inspection at Rumpke Recycling and Transfer Station
Location: Fields Ave., Columbus, Ohio
Permit Number 4GC03126*AG**

Dear Mr. Drobina:

This letter is written in follow-up to a construction storm water inspection I conducted of the construction activities associated with Rumpke Recycling and Transfer Station located on Fields Ave., in Columbus, Ohio on November 4, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues:

Sediment and Erosion Control:

- Perimeter silt fence appears to be in good repair, with the exception of minor maintenance issues along the eastern perimeter. Please ensure all silt fence is properly maintained.
- All barren areas which remain idle over the winter months must be protected from erosion. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion controls, such as a crimped mulch cover are expected.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



David Murphy
Rumpke
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at: harry.kallipolitis@epa.state.oh.us.

Sincerely



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor

HK/nsm Rumpke Recycling 11-4-2010