



\*4GC0324320110829\*

2011/08/29

4GC03243

CROSSROADS CHRISTIAN CHURCH



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 29, 2011

Mr. Cooper and Mr. Campbell  
Master Church Builders  
1667 Gateway Circle  
Grove City, OH 43123

**Re: Crossroads Christian Church / Fayette County  
Construction Storm Water Permit 4GC03243\*AG**

Dear Mr. Cooper and Mr. Campbell:

This letter is written in follow-up to a construction storm water inspection that I conducted at Crossroads Christian Church, located at 175 Halliday Way, in Washington Court House, Ohio on August 23, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Please be aware the General Permit states that all barren areas including soil stockpiles which remain idle in excess of 21 days must be protected from erosion within 7 days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven days. Most of the entire site was barren and appeared to be at final grade. Please stabilize the site. Please see attached pictures.
- Please be aware that erosion controls should be installed at the site until there is a good vegetative growth. There were no erosion controls at the site. Please install erosion controls, i.e., silt fence and dandy bags, until there is a good growth of grass. Please see attached pictures.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at [greg.sanders@epa.state.oh.us](mailto:greg.sanders@epa.state.oh.us).

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure


c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Crossroads Christian Church, August 23, 2011


Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)





Crossroads Christian Church  
Stabilize barren areas  
Paint Creek Watershed  
August 23, 2011  
Photo by: Greg Sanders



Crossroads Christian Church  
Install erosion controls  
Stabilize barren areas  
Paint Creek Watershed  
August 23, 2011  
Photo by: Greg Sanders

