



4GC0243720110822

2011/08/22

4GC02437

FAIRFIELD UNION HIGH SCHOOL



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 22, 2011

Jim Herd
Fairfield Union Local School District
6401 Cincinnati-Zanesville Road
Lancaster, OH 43130

Re: Fairfield Union High School / Fairfield County

Dear Mr. Herd:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Fairfield Union High School project along State Route 22. This site is located at 6401 Cincinnati-Zanesville Road near Rushville, Ohio and the inspection was conducted on August 3, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. It appeared during the inspection that construction activity has been completed for this site and all disturbed areas had been permanently stabilized. Please address the following:

Post Construction Requirements:

The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate that your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at greg.sanders@epa.state.oh.us.

If you have not already done so, a Notice of Termination will be required providing that the post construction requirements have been met. Instructions and forms can be found at <http://www.epa.state.oh.us/dsw/storm/stormform.html>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Jonathan I. Ferbrache, Fairfield Soil and Water Conservation District
Kevin Mohler, Bovis Lend Lease

GS/nsm Fairfield Union HS, August 3, 2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

