



4GC0353520110818

2011/08/18

4GC03535

PHOENIX MIDDLE SCHOOL



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 18, 2011

Tim Gehring
Worthington City School District
200 East Wilson Bridge Road
Worthington, OH 43085

**Re: Construction Storm Water Inspection at Phoenix Middle School
Franklin County
Permit Number: 4GC03535*AG**

Dear Mr. Gehring:

This letter is written regarding a storm water inspection conducted by Greg Mann and Daelann Farnlacher of the Ohio EPA at Phoenix Middle School located at 2341 Snouffer Road Worthington, Ohio on August 8, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appears that storm water is contained within the site's current excavation. Please ensure all storm water remains contained as construction progresses. In the event off-site positive drainage is established additional controls will be required.

Please ensure all dewatering activities do not result in turbid discharges to waters of the state or an associated conveyance such as a separate storm sewer system

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Tim Gehring
Worthington City School District
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



J. Bohne
FOR HK

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Phoenix Middle School 8-5-2011