



\*4GC0287820110818\*

2011/08/18

4GC02878

HOLIDAY INN PRIVATE ACCESS RD



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 18, 2011

Nitin Patel  
Badriushal LLC  
600 Enterprise Drive  
Lewis Center, OH 43035

**Re: Construction Storm Water Inspection at Holiday Inn Private Access Road /  
Delaware County  
Permit Number: 4GC02878\*AG**

Dear Mr. Patel:

This letter is written regarding a storm water inspection I conducted at Holiday Inn Private Access Road located at the intersection of Polaris Parkway and Orion Place in Columbus, Ohio on August 2, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- It appears that the majority of the barren areas have been protected from erosion as requested in the previous inspection reports.
- Please continue to monitor vegetation to ensure a successful vegetation cover to control erosion, measured by a minimum vegetation density of 70 percent.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Nitin Patel  
Badriushal LLC  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. Bohne' with 'FOR HK' written below it.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO