



4GC0312920110818

2011/08/18

4GC03129

ETNA PARKWAY



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 18, 2011

Jerry Brems
Licking County
20 South Second Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at Etna Parkway / Licking County
Permit Number: 4GC03129 *AG**

Dear Mr. Brems:

This letter is written regarding a storm water inspection I conducted at Etna Parkway located between US 40 and State Route 16 in Pataskala, Ohio on August 8, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please ensure all recently disturbed areas associated with Phase 2 of project, including the large stock pile, are adequately protected from erosion within application of seed and mulch.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Etna Parkway 8-8-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

