



4GCO000520110818

2011/08/18

4GCO0005

DACC DRIVE IMPROVEMENTS



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 18, 2011

Mathew Weber
City of Delaware
1 South Sandusky Street
Delaware, OH 43015

**Re: Construction Storm Water Inspection at DACC Drive Improvements / Delaware
County
Permit Number: 4GCO00050*AG**

Dear Mr. Weber:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Lauren Burns of the Ohio EPA at DACC Drive Improvements located at 4565 Columbus Pike Delaware, Ohio on August 8, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Our staff noted several storm drains on site that lacked inlet protection from sediment (see Figure 1). Please take immediate corrective measures to minimize sediment laden discharges to waters of the state.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office


c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm DACC Drive Improvements 8-8-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov





DACC Road Improvement
Clentangy River Water
Photo by: Lauren Burd
8-6-11

Figure 1

