



\*4GC0336820110816\*

2011/08/16

4GC03368

SOUTH HIGH RISE DORMS (SMITH HALL & STEEB  
HALL)



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 16, 2011

Kristin Poldemann  
Ohio State University  
400 Central Classroom Building  
2009 Millikin Road  
Columbus, OH 43210

**Re: Construction Storm Water Inspection at South High Rise Dorms (Smith Hall and Steeb Hall) / Franklin County  
Permit Number: 4GC03368 \*AG**

Dear Ms. Poldemann:

This letter is written regarding a storm water inspection I conducted at the South High Rise Dorms located at 92 West 11<sup>th</sup> Avenue and 70 West 11<sup>th</sup> Avenue on July 29, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- During the inspection, it was noted that the perimeter controls for this site have failed and will require maintenance.
- It appears this site is currently under construction. However, the controls must be maintained to minimize sediment laden discharges from the site.
- Please ensure all dewatering activities associated with this site do not result in turbid discharges to waters of the state.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Kristin Poldemann  
Ohio State University  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



*J. Boh*  
*For HK*

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO