



4GC0334820110816

2011/08/16

4GC03348

WILLIAM H HALL COMPLEX



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 16, 2011

Ruth Miller
Ohio State University
400 Central Classroom Building
2009 Millikin Road
Columbus, OH 43210

**Re: Construction Storm Water Inspection at William H Hall Complex
Franklin County
Permit Number: 4GC03348 *AG**

Dear Ms. Miller:

This letter is written regarding a storm water inspection I conducted at William H Hall Complex located on the northwest corner of the 10th Avenue and Worthington Street intersection on July 29, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection, it was noted that the perimeter controls for this site have failed and will require maintenance.
- Please ensure all dewatering activities associated with this site do not result in turbid discharges to waters of the state.


Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ruth Miller
Ohio State University
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



For HK

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm William H Hall Complex 7-29-2011