



\*4GC0353720110815\*

2011/08/15

4GC03537

WORTHINGWAY MIDDLE SCHOOL



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 15, 2011

Tim Gehring  
Worthington City School District  
200 East Wilson Bridge Road  
Worthington, OH 43085

**Re: Construction Storm Water Inspection at Worthingway Middle School  
Franklin County  
Permit Number: 4GC03537\*AG**

Dear Mr. Gehring:

This letter is written regarding a storm water inspection conducted by Greg Mann and Daelann Farnlacher of the Ohio EPA at Worthingway Middle School located at 6625 Guyer Street Worthington, Ohio on August 5, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Please maintain the clogged dandy bag located at the entrance to the site (see Figure 1).
- It appears the current excavation of the site contains all storm water. Please ensure all storm water remains contained as construction progresses.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Tim Gehring  
Worthington City School District  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Handwritten signature of Harry Kallipolitis in cursive, with the initials "HK" written below it.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office


c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Worthingway Middle School 8-5-2011



**Figure 1: Storm drain requires appropriate inlet protection**





Worthingway Middle School  
Oventangy River Watershed  
Photo By: Daisann Farnbacher  
Dandy bag at entrance to site

8/5/2011 10:18

Figure 1

